

3 door Interlock

Note:
The door monitor and lock monitor should be closed circuit when the door is closed and the lock is locked. Egress buttons should be push to make

